

ALTERATION – PHASE 1

**WINDERMERE ELEMENTARY SCHOOL  
2 ABBOTT ROAD  
ELLINGTON, CT 06029  
STATE PROJECT NO. 048-0059 A**

S/P+A PROJECT NO. 12.253

**DATE: January 17, 2014**

The following changes to the Drawings and Project Specifications shall become a part of the Drawings and Project Specifications; superseding previously issued Drawings and Project Specifications to the extent modified by Addendum No. 6.

**General Information/Clarifications:**

- See attached RFIs. (2)
- See attached prebid meeting sign-in sheet for reference. (1)

**Changes to Addenda:**

- ADDENDUM #5, Section 087100, Door Hardware, Page 6, Article 2.3.D.2., add the following:  
  
“a. Provide indicator rose with all classroom security locksets.”

**New Drawings:**

- DRAWING CSK-02, FIRE LANE, CROSSING & BUS DROP-OFF STRIPING has been added and is attached as part of this addendum. This sketch adds information to Drawing C-501.

**The bid date remains Wednesday, January 22, 2014 at 2:00pm by this addendum.**

The addendum consists of four (4) pages of 8½” x 11” text and one (1) 8½” x 11” drawings.

End of Addendum #6

**From:** Rebecca Bouchard  
**Sent:** Wednesday, January 15, 2014 4:24 PM  
**To:** 'aaajack@sbcglobal.net'  
**Cc:** Dustin Lombardi  
**Subject:** FW: RFI, Windermere School, pavement markings  
**Attachments:** 2014-01-13 CSK-02 Striping.pdf

Jack, please see the responses (in red) to your RFI below.  
Thank you and have a great day.

Rebecca Bouchard, CSI, CDT  
Intern Architect

[www.silverpetrucelli.com](http://www.silverpetrucelli.com)

SILVER / **PETRUCELLI + ASSOCIATES**  
*Architects/Engineers/Interior Designers*

3190 Whitney Avenue Bldg 2  
Hamden, Connecticut 06518  
P: 203-230-9007 ext. 202  
F: 203-230-8247  
*S/P+A is a member of the U.S. Green Building Council*

---

**From:** jack kearns [<mailto:aaajack@sbcglobal.net>]  
**Sent:** Saturday, January 11, 2014 1:58 PM  
**To:** Paul Jorgensen  
**Subject:** RFI, Windermere School, pavement markings

Hi Paul,

I met you at the walk thru Saturday. I did find the existing and demo sheets. I've gone over the specs and drawings and have a few questions I'd like to ask.

- 1.) The spec 321723 mentions a number of different materials; water bourne traffic paint, hot applied paint, epoxy markings, temporary plastic markings, with and without glass beads, etc. Sheet C-501 specifies white painted lines. The existing markings appear to coincide with C-501 and are standard water bourne traffic markings without glass beads. This is what is typically used in parking lots. Is a standard water bourne traffic paint the desired material to use? I happen to use paint manufactured by the Franklin Paint Co in Franklin, MA. **Standard waterbourne paint is acceptable.**
- 2.) C-100 refers to removing existing pavement markings but does not specify what is acceptable. Is painting the conflicting markings black an acceptable method? Some of the pavement is old and cracked. If the pavement markings were to be ground off, damage to the pavement may result. **Painting black over the existing markings is acceptable.**
- 3.) C-200 shows the new pavement. That is fine. No questions there.
- 4.) C-400 shows painting the newly paved areas. It does not show any painting over the existing markings. Is this true that the new pavement areas are the only areas that are to be painted? The existing markings are to be left as is other than removing the conflicting markings as detailed in question 2 above. **Yes, the existing markings (that are not in conflict with new markings) are to remain.**

5.) C-400 depicts a fire lane. The spacing between the diagonal lines appear to be different than the spacing on the other side of the island which states to match handicap striping. Is there a detail for the fire lane striping or is this also to match the handicap striping? **The fire lane, crossing and bus drop striping shall be as depicted in CSK-02 (attached).**

6.) C-400 shows fire lane stencils. The existing fire lane stencils are 18" in height. Is that an acceptable size for the new work? **18" is acceptable.**

Thank you for your time.

Jack Kearns,

AAA Pavement Marking, LLC

860-745-2187

WINDERMERE

10:30-12:30

SIGN-IN

1/11/2014


Jack Reams AAA Payment Marketing

Tom Cleary Keltic Painting

Sy Posocco EASTERN ELECTRIC

860-684-2994

Joe Ruiz ZLOTNICK CONST



PREPARED FOR:

SILVER PETRUCELLI + ASSOCIATES  
3190 WHITNEY AVENUE  
HAMDEN, CT 06518

FIRE LANE, CROSSING AND  
BUS DROP-OFF STRIPING

WINDERMERE ELEMENTARY SCHOOL  
2 ABBOT ROAD  
ELLINGTON, CT

 **BSC GROUP**

180 Glastonbury Boulevard  
Suite 103  
Glastonbury, Connecticut 06033  
860 652 8227

Job No.: 048-0059A Date: 2014-01-13  
Scale: N.T.S. Revised: \_\_\_\_\_  
Dwg. No.: CSK-02 Figure: \_\_\_\_\_